




# How to manage a 60 to 200 amp load using a SMM Module and Magnetic Latching Relays



**Step One: Remove the spade terminal with the BLUE, RED and BLACK wires shown from the contactor**



**Step Two: Plug the Blue, Red and Black extender wires with isolated spade terminals provided into the Blue, Red and Black wires from the control board.**



**Step Three: Mount or nipple the SMM module to the relay enclosure. Connect the black wire to the left terminal "IN" on the relay. Connect the red wire to the right terminal "IN". Connect the blue wire to Pin 1 on the control board. The SMM module now has full control of the relay and the relay will turn on and off based on the SMM modules instructions.**